



Department of Finance, Government of Madhya Pradesh
Acknowledgement Receipt for Online Tax Payment
to M.P. State Government



TIN (Tax payment Identification Number) / Enrollment / Registration No.	-
Depositor/Dealer Name	PRINCIPAL
Address	IN FRONT OF RTO OFC, CRESCENT RESORT CROSS ROAD, SEHORE, Sehore, Madhya Pradesh - 466001
District selected for Payment	Sehore
Unique Registration Number (URN)	MPTURN170820230001211
Department and Office Name	Common Challan Entry, Public Health Engineering
Challan Payment Period	2023-2024

Purpose Details

CRN	Assessment/ Concerning Period	Head of Account	Challan Identification Number (CIN)	Challan No.	Amount(Rs.)
MPT021517082023000003	2023-08-17 to 2023-09-18	0215-01-104-0000 (Fees, Fines, etc.)	SBIN0006159021517082023430662	051/9999999/0215/08/23/000114	1200.00

Total Amount(in figures)	1,200.00
Total Amount(in words)	One Thousand Two Hundred Rupees Only
Name and Code of the Bank	STATE BANK OF INDIA (2)
Bank Reference Number	CPACZUWQB
Scroll No	43066
Scroll Date	17/08/2023
Date of Transaction / Time of Transaction (HH24:mm:ss)	17/08/2023 11:44:25
Transaction Status	Success

नोट:- आचार्य कुंभा शिक्षा परिसर सीहोर द्वारा एक परिसर शुल्क ₹१२००.०० दिनांक 17/08/2023 को जमा किया गया!

Narendra Kumar
Quality Manager
Narendra Kumar
DWTL PHE D Sehore

DISTRICT WATER TESTING LABORATORY
Public Health Engineering Department, Sehore Email: eephseh@nic.in

ULR No.

T	C	0	0	0	0	2	3	0	0	0	0	0	0	5	4	F
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

TEST REPORT

Nature of sample :-	Drinking Water	<i>NOT SAMPLED BY DIST. LAB</i>				
Sender's name and address:- PRINCIPAL KANYA SHIKSHA PARISAR, SEHORE	Quantity Of sample	Sufficient	Sender's letter no.	-	Sender's letter Date	17/08/2023
	Condition of Sample	ok	DWTL Ref. No	54	DWTL receipt date	17/08/2023
			Date of analysis started	17/08/2023	Date of analysis completed	18/08/2023

Sample details

No	Block	Gram Panchayat	Village /Habitation	Location
1	SEHORE	----	SEHORE	IN FRONT OF R.T.O. OFFICE, SEHORE
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				

Field..Testing

Discipline.. Chemical

Group..Water

Sub Group..Drinking Water

Details of parameters , their test methods, units and specifications as per BIS

No.	Characteristics	Test method	Unit	As Per BIS -10500:2012 For Drinking Water	
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source
1	pH	IS 3025(P-11) 1983	pH scale	6.5-8.5	6.5-8.5
2	Turbidity	IS 3025(P-10) 1984	NTU	1.0	5.0
3	Colour	IS 3025(P-04) 2021	Hazen Scale	5	15
4	Total Hardness	IS 3025(P-21) 2009	mg/l	200	600
5	Calcium	IS 3025(P-40) 1991	mg/l	75	200
6	Magnesium	APHA 23 rd Edition 3500 Mg-B	mg/l	30	100
7	Total Alkalinity	IS 3025(P-23) 1986	mg/l	200	600
8	Chloride	IS 3025(P-32) 1988	mg/l	250	1000
9	Fluoride	IS 3025 (P-60) 2013	Mg/l	1.0	1.5
10	Nitrate as NO ₃	IS 3025(P-34) 2022	Mg/l	45	45
11	Sulphate as SO ₄	IS 3025 (P-24) Sec 1 2022	Mg/l	200	400
12	TDS By Meter	IS 3025	Mg/l	500	2000
13	Iron as Fe	IS 3025 (P-53) 2019	Mg/l	1.0	1.0
14	Manganese as mg/l	IS 3025 (P-59) 2006	Mg/l	0.1	0.3

- This report should not be produced partly or full without approval of signatory authority for legal purposes .
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" in column 6, above which the sources will have to be rejected.
- The results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- Remarks:

Narendra
Analyst

ISSUE No. 54 /DWTL/PHE/D/SEHORE / ISSUE DATE:-18/08/2023

Narendra
Signatory Authority
Quality Manager
Narendra Kumar
DWTL PHE D Sehore